

LINCO ENTERPRISES / NEXXACORE

TEST REPORT

SCOPE OF WORK

Canvas

REPORT NUMBER

221014011SHF-004

TEST DATE(S)

2022-10-14 - 2022-11-01

ISSUE DATE

2022-11-01

PAGES


6

DOCUMENT CONTROL NUMBER

LFT-APAC-SHF-OP-10k(September 1, 2022)

© 2022 INTERTEK

Intertek Testing Services Shenzhen Ltd. Shanghai Fengxian Branch



Test Report

Statement

- 1.This report is invalid without company's special seal for testing on the assigned page.
- 2.This report is invalid without an authorized person's signature.
- 3.This report is invalid if altered.
- 4.Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Don't copy this report in partial without any official approval in written by our company. This report is invalid without re-stamping the special seal for testing in copying report.
- 5.This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample(s) tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.
- 6.Except for the obligation, responsibility and liability (if any) for the appropriateness and professionalism of afore-mentioned testing itself within the scope and amount of the testing fee received, Intertek does not and will not accept any other obligation or liability.
- 7.If the Client has any questions about the test results, Intertek B&C should be informed within the storage period of the samples. The sample storage period ends 5 working days after the official report issue date. Samples of certification program are retained for the period required by the certification rules. The samples storage period shall be calculated according to the issue date of the original report in the case of quoting results and modifying reports.
- 8.Intertek B&C will service this report for the entire test record retention period. The test record retention period ends 6 years after this report original issue date. The test record retention period for certification program is 10 years. Test records and other pertinent project documentation will be retained for the entire test record retention period.



Test Report

Issue Date: 2022-11-01 Intertek Report No. 221014011SHF-004
Applicant: LINCO ENTERPRISES / NEXXACORE
Address: 13626 MONTE VISTA AVE, STE B, CHINO, CA 91710
Attn: Carl
Test Type : Performance test, samples provided by the applicant.

Product Information

Product Name	Canvas	Brand	NexxaCore Masterpiece Collection
Sample Description	Good Condition	Sample Amount	40 pcs
		Received Date	2022-10-14
Sample ID	Model	Specification	
S221014011SHF.002	20-122G3-1002	228*1800*8.0MM	

Test Methods And Standards

Test Standard	ASTM E90-09(R2016)
Specification Standard	ASTM E413-16
Test Conclusion	The samples were tested according to the above standards, and the results are shown in the following page.

Note:

1.This report does not involve sampling. The report only reflects conformity of the tested items of the samples provided by the testing applicant. Representativeness and authenticity of the submitted samples are responsibilities of the testing applicant.

Report Authorized



Name: Ozzy Cheng Title: Reviewer

Name: Jackie Zhou Title: Project Engineer

Test Report

Issue Date: 2022-11-01

Intertek Report No. 221014011SHF-004

Test Items, Method and Results:

Test Item: Laboratory Measurements of Airborne Sound Transmission Loss

Test method: ASTM E90-09(R2016)


Temperature: 22 °C Relative Humidity: 50 %

Volume of Source Room: 77 m³ Volume of Receiving Room 112 m³

Specimen area: 11.9 m²

Floor Assemblies: The system consisted of 150mm thick concrete floor and the 8mm Canvas Floors (including 1.5mm IXPE underlayment) were placed on the concrete floor.

Mounting of the Floating installation with click joints



Calculated Sound Transmission Class: STC 52

Note:

1. TL = Transmission loss
2. Classified STC in accordance with ASTM E413-16, Classification for Rating Sound Insulation. The methods of calculating single- number acoustical ratings for laboratory measurement of sound attenuation obtained in one-third octave bands.
3. The STC was for the whole floor assemblies.

Test Report

Issue Date: 2022-11-01

Intertek Report No. 221014011SHF-004

Test Photos:



Test set up

Test Report

Issue Date: 2022-11-01

Intertek Report No. 221014011SHF-004

Appendix A: Sample Received Photo



Revision:

NO.	Date	Changes
221014011SHF-004	2022-11-01	First issue